Avalanche Impact Performance of a Guyed Steel Diversion Structure Tower 4-6 138 kV Transmission Line Snettisham, Southeast Alaska

Chris Wilbur Mike Janes Art Mears





Photo: AEL&P

# **Snettisham Tower 4-6**

### Outline

- ✓ Site & Climate
- ✓ History
- ✓ 2012 Weather & Avalanche impact
- ✓ Observations & Measurements
- Analysis Back calculations
- ✓ Conclusions



Speel Shoulder - Photo: Don Sharaf



# Climate

ANNUAL PRECIP.	
Anchorage	40 cm.
Juneau airport	148 cm
Juneau downtown	228 cm
Snettisham	350 cm







# HISTORY

1910 Speel Arm Paper Mill 1967-73 Transmission Line Constructed April 1976 Avalanche Tower 4/6 moved 1981 April 16, 2008 Avalanche 2009 Steel Diversion Structure March 8, 2012 Structure Hit Light-weight Guyed Porous Steel Splitting Wedge Diversion Structure

- 11 meters tall
- > 37 degree apex
- > Asymmetric
- Internal braces
- Steel guys
- Gaps in wings





### WEATHER & SNOWPACK

- February Weak Layer
- March 20 cm SWE storm



2012 vs. 2008 AVALANCHE Lower Elevation Crown Colder Snowpack Earlier Event Lower Snow Depth

## **Before Impact**





### 2012 DEBRIS DEPTHS

Dense Debris 3.4 to 5.5 meters

Dry snow (saltation) 1.0 to 1.5 meters

Structure Height 11 meters

### Guy Cable Slack (cm)



- Measured during re-tensioning.
- Non-Uniform
  leading guy
  left wing.
- Elongation < 0.5 percent</p>



#### INTERIOR DEBRIS HEIGHTS (meters)

- ✓ Non-uniform
- ✓ Thicker (2m) towards back
- $\checkmark$  Thinners (1m) at apex
- ✓ No debris impacted lattice tower

## 2012 vs. Design Avalanche



Design snow depth

Avalanche type: dry flowing

Flow Height

Velocity & Density (impact energy)

Powder component (stagnation pressure)

## Conclusions



Impact Loads Steel Guy Cables Gaps in Wings Internal Braces

### Future Structures



Bill Glude Photo

## Thank You!



Acknowledgements

Alaska Electric Light & Power Dryden & LaRue